



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

November 19, 2007 **RE-ISSUED 7/28/2008**

DELTA ENVIRONMENTAL PRODUCTS, INC.
MIKE CATANZARO
PO BOX 969
DENHAM SPRINGS LA 70727

UV "THE DISINFECTOR" INC
KEN MOODY
PO BOX 203
PUYALLUP WA 98371

Re: Description: SEWAGE TREATMENT- ULTRAVIOLET DISINFECTION
Manufacturer: UV "THE DISINFECTOR" INC
Product Name: UV DISINFECTION UNIT
Model Number(s): 6 GPM
Product File No: 20070511

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of November 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- Installation and maintenance of this product must be in accordance with the manufacturer's printed installation and maintenance instructions.
- System must be maintained at least once every 6 months.
- The wastewater flow discharge through this product must be equal to or less than 6 gallons per minute.
- The wastewater received by this product must have a BOD5 and TSS value of equal to or less than 30 mg/L.
- When this product is installed in a tank, the tank must be approved by the Department of Commerce, Division of Safety and Buildings for use with this product.
- An access opening of sufficient size and location to allow servicing of this product must be provided. This access opening must terminate at or above finish grade.
- The wastewater discharged from this product will have a Fecal Coliform value of equal to or less than 10,000 cfu/100ml.

This approval supersedes the approval issued on Oct. 9, 2003 under product file number 20020235. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020235.

7/28/08 re-issued due to error in model no. on file. 6 GPM

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov